

# **Bid for WGRSG 2025 Security Camera Replacements Stadium Authority of Pittsburgh**

*Addendum #1  
March 12, 2025*

**Please acknowledge receipt of this addendum in your bid submission.**

**Additional Documents attached at this [link](#):**

**Sign-in sheet**

**Meeting Agenda**

A non-mandatory pre-bid meeting and walkthrough was held onsite on March 11, 2025, at 11am.

**All inquiries regarding this Bid are due by 5pm on Thursday March 14, 2025.** Please submit all questions in writing via email to Steve Morrison at: [procurement@pgh-sea.com](mailto:procurement@pgh-sea.com). You will receive a confirmation that we've received your questions. The response to all received questions will be posted as an addendum.

**Bids are due Wednesday, March 19, 2025, by 12:00pm**

## **Pre-bid meeting summary:**

During the pre-meeting meeting, the BID was reviewed including all dates and scope requirements. The contract, MBE/WBE, and diversity requirements were discussed. This is a prevailing wage project, and the Stadium Authority appreciates your help reaching our MBE/WBE goals.

## **Questions from the pre-proposal meeting:**

**Q: Is the existing cabling in good condition.**

A: Yes, the existing coax cabling is in working condition. We have images currently from all locations where analog cameras are to be replaced. It is expected that the ends will be re-terminated to ensure good connectivity.

**Q: Item #1 refers to Genetec licenses to be purchased from Dagastino Electronic Services, can we provide the license instead.**

A: No. Dagastino is our current support vendor for our Genetec platform and will make the purchase of the license and true up its software assurance with our existing site license and update our license. The successful bidder will pay Dagastino for these licenses. A quote can be obtained from Dagastino for the license and installation of the license. Please include this amount on your bid form for item 1. Please reach out to Mark Nardello ([mnardello@descomm.com](mailto:mnardello@descomm.com)) at Dagastino for this quote.

**Q: Can you provide a location description and photos of the existing camera specified in the scope as item #17 (4<sup>th</sup> Floor Speed Ramp camera.)**

A: Three photos can be found below. The camera is in the Northwest corner of the 2<sup>nd</sup> level parking deck on the back side of the building. It can be accessed from the bottom of the speed ramp located on the back side of the parking structure.





