

Chiller Plant – Condenser Isolation Valves

AT THE DAVID L. LAWRENCE CONVENTION CENTER

The Sports & Exhibition Authority will receive pricing for the purchase of two 12” condenser isolation valves and the removal and install of three 12” condenser isolation valves, with one pre-purchased by the owner at the David L. Lawrence Convention Center. Inquiries regarding this opportunity should be made to Morgan Schmitt, Facilities Manager, e-mail: procurement@pgh-sea.com, phone: 412.325.6137. There is no formal bid for this project. For details on scope of work, please contact Morgan Schmitt.

General Scope:

- Removal and installation of three 12” condenser isolation valves.
 - o Work to be completed on Chiller 1, 2, and 4.
 - o One valve has been purchased by owner.
 - o Two valves to be purchased by contractor.
 - o Remove and replace insulation on the three valves.
 - o Access/scaffolding to be provided by contractor. Lifts can be provided by DLCC.
 - o Valve Detail:
 - Milwaukee Valve: MIL-ML333E-091
 - 12” ULTRA – PURE BFLY
 - Ductile Iron, Lug
 - Operator: Gear
 - NSF/ANSI 372 8 61
 - Aluminum Bronze, EPDM
 - 416 Stem

Written quotes will be due at 2:00pm on Monday, October 21, 2024.

Quotes should be submitted via email to procurement@pgh-sea.com.