



Addendum #2 – Exhibit Hall/Service Corridor Lighting Upgrades

April 8, 2024

1) Dates:

- a) Deadline for Inquiries: 2:00pm | April 9, 2024
 - i) Email: lkistler@pittsburghcc.com
- b) Deadline for Submission of Bids: 4:00pm | April 18, 2024
 - i) Bids must be dropped off at the DLCC (East Lobby) prior to 4:00pm.
 - (1) The bids will be publicly opened at 4:00pm.

2) Additional Information:

- a) Contact Information
 - i) SEA Procurement & M/WBE Specialist
 - (1) Alicia Matos
 - (a) Email: amatos@pgh-sea.com
 - (b) Phone: 412.393.7106

3) Questions:

- a) Are we permitted by code to install a PDC control to dim a duplex receptacle?
 - i) The 2017 NEC code doesn't state that you can't use a phase adaptive dimming power pack to dim a receptacle. The existing receptacle is in the ceiling space at the height level of the existing track lights and is a dedicated receptacle for the track lights.
- b) Do we have to remove the ballast from the high bay fixture and recycle the ballast?
 - i) Yes – please reference Construction Waste Management and Disposal Plan in Bid Package.
- c) Do we have to remove the ballast from the 2x4 lay-ins and recycle the ballast?
 - i) Yes – please reference Construction Waste Management and Disposal Plan in Bid Package.