



## **Sports & Exhibition Authority**

When you have the time, Pittsburgh has the place.

### Addendum #2 – North Façade Metal Panel Stabilization – DLLCC

September 26, 2023

#### **1) Dates:**

- a) Deadline for submission of bids has been **extended – Tuesday, October 3<sup>rd</sup> @ 3:00pm**
  - i) Bids must be dropped off at the DLLCC prior to the deadline
  - ii) The public bid opening will be held at the DLLCC at 3:00pm

#### **2) Additional Information:**

- i) To coordinate onsite visits
  - (1) Spencer Girman
    - (a) [sgirman@pittsburghcc.com](mailto:sgirman@pittsburghcc.com)
    - (b) 412-325-6137

#### **3) Questions:**

- a) **Is it feasible to remove and re-stabilize the panels solely from the exterior of the building as opposed to having to demo the ceiling/grid inside and provide special access to the backside of the panels?**
  - i) Since the existing cold-formed metal framing doesn't align with the panel joints, we are not comfortable with any long-term anchorage solution that would only be engaging drywall sheathing. Even if framing elements were present that line up with the panel joints, we would still recommend that the interior space be accessed to ensure that the new anchors actually engage the framing members.